

## SECTION 27 05 28.28

### FIRESTOPPING TELECOMMUNICATIONS AND DATA CABLING

#### PART 1 - GENERAL

##### 1.1 SUMMARY

- A. This section includes Labor, materials and equipment necessary to complete the installation required for the items specified under this Section, including but not limited to:

1. Firestopping of Through Penetrations in Fire Rated Assemblies.

##### 1.2 RELATED SECTIONS

- A. Related Work: Consult all other Sections, determine the extent and character of related work and properly coordinate work specified herein with that specified elsewhere to produce a complete installation.
- B. This Specification should be considered as an augmentation to Section 07 84 00 Firestopping and any or all sub sections of Section 07 84 00.
- C. This Section address those unique elements that affect the Firestopping of Information Technology cabling systems which my not be addressed in 07 84 00 or any of its sub-sections.

##### 1.3 REFERENCES

- A. ASTM E 814, "Fire Tests of Through Penetration Firestops".
- B. ANSI/UL1479, "Fire Tests of Through Penetration Firestops".
- C. Underwriters Laboratories Inc. (UL) – Fire Resistance Directory
- D. National Fire Protection Association (NFPA) – NFPA 101: Life Safety Code.
- E. National Fire Protection Association (NFPA) – NFPA 70: National Electrical Code.

##### 1.4 PERFORMANCE REQUIREMENTS

- A. Fire rated cable pathway devices shall be used for ALL low-voltage, video, data and voice cabling, optical fiber raceways and certain high-voltage cabling where frequent cable moves, adds and changes may occur. Pathways required for high voltage cabling will be detailed on the prints. Such devices shall:
1. Meet the hourly fire-rating of fire rated wall and or floor penetrated.
  2. Be tested for the surrounding construction and cable types involved.
  3. Have UL Systems permitting cable loads from; "Zero to 100% Visual Fill." This requirement eliminates need for fill-ratio calculations to be made by

cable technicians to ensure cable load is within maximum allowed by UL System.

4. Not have inner fabric liner that tightens around and compresses cables tightly together encouraging alien cross-talk interference.
  5. Be "Zero-Maintenance", zero-maintenance is defined as; No action required by cabling technician to open and/or close pathway for cable moves, adds or changes, such as, but not limited to:
    - a. Removal and or replacement of any material such as, but not limited to, firestop caulk, putty, pillows, bags foam muffins, foam blocks, or foam closures of any sort.
    - b. Opening or closing of doors.
    - c. Spinning rings to open or close fabric liner.
    - d. Furnish letter from manufacturer certifying compliance with this definition of "Zero-Maintenance".
  6. Pathways shall be engineered such that two or more devices may be ganged together for larger cable capacities.
  7. Pathways shall be engineered to be re-enterable so they can be retrofitted and removed from around existing cables without cutting and re-splicing them.
  8. Affix adhesive wall label immediately adjacent to devices to communicate to future cable technicians, authorities having jurisdiction and others the manufacturer of the device and the corresponding UL System number installed.
- B. Where non-mechanical pathways must be utilized, such as sealing (caulking) around single or grouped conduits, provide products that upon curing do not re-emulsify, dissolve, leach, breakdown or otherwise deteriorate over time from exposure to atmospheric moisture, sweating pipes, ponding water or other forms of moisture characteristic during or after construction. Provide letter from manufacturer certifying compliance with this section.
- C. Cable pathway shall replace conduit sleeves in walls and floors, and;
  - a. When installed individually in floors, devices shall pass through core-drilled opening utilizing tested floor plates.
  - b. When multiple units are ganged in floors, devices shall be anchored by means of a tested grid.
  - c. When installed individually in walls, devices shall pass through core drilled opening utilizing tested wall plates.
  - d. When multiple units are ganged in walls, devices shall be anchored by means of a tested grid.
- D. Cable tray shall terminate at each fire barrier and resume on the other side such that cables pass independently through devices. Cable tray shall be properly supported on each side of fire barrier.

**Note to Specifier: Coordinate drawings to show tray terminating at wall or floor and resuming on other side.**

#### 1.5 SUBMITTALS

- A. Submit under provisions of Section 01 30 00.

- B. Product Data: Provide manufacturer's standard catalog data for specified products demonstrating compliance with referenced standards and listing numbers of systems in which each product is to be used.
- C. Schedule of UL System Drawings: Submit schedule of all expected opening locations and sizes, penetrating items, and required listed design numbers to seal openings to maintain fire resistance ratings. If engineering recommendations are necessary, list these in the schedule too.
- D. UL System Drawings: Furnish copies of all UL Systems identified in schedule above. Include any engineering recommendations.
- E. Certificates: Product Certificate of Compliance from the by firestop system manufacturer certifying material compliance with applicable code and specified performance characteristics.
- F. Installation Instructions: Submit manufacturer's printed installation instructions.

#### 1.6 QUALITY ASSURANCE

- A. Products/Systems: Provide firestopping systems that comply with the following requirements:
  - 1. Firestopping tests are performed by a qualified, testing and inspection agency. A qualified testing and inspection agency is UL, or another agency performing testing and follow-up inspection services for firestop system acceptable to authorities having jurisdiction.
  - 2. Firestopping products bear the classification marking of qualified testing and inspection agency.
- B. Installer Qualifications: Experience in performing work of this section who is qualified by the firestopping manufacturer as having been provided the necessary training to install firestop products in accordance with specified requirements.

#### 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Delivery:
  - 1. Manufacturer's original, unopened, undamaged containers, identification labels intact identifying product and manufacturer, date of manufacture; lot number; shelf life, if applicable; qualified testing and inspection agency's classification marking; and mixing instruction for multi-component products.
  - 2. Handle and store products according to manufacturer's recommendations published in technical materials. Leave products wrapped or otherwise protected and under clean and dry storage conditions until required for installation.
- B. Storage and Protection:

1. Store materials protected from exposure to harmful weather conditions and at temperature and humidity conditions recommended by manufacturer.

## 1.8 PROJECT CONDITIONS

- A. Do not install firestopping products when ambient or substrate temperatures are outside limitations recommended by manufacturer.
- B. Do not install firestopping products when substrates are wet due to rain, frost, condensation, or other causes.
- C. Maintain minimum temperature before, during, and for a minimum 3 days after installation of materials.
- D. Do not use materials that contain flammable solvents.
- E. Coordinate construction of openings and penetrating items to ensure that through-penetration firestop systems are installed according to specified requirements.
- F. Coordinate sizing of sleeves, openings, core-drilled holes, or cut openings to accommodate through-penetration firestop systems.
- G. Schedule installation of firestopping after completion of penetrating item installation but prior to covering or concealing of openings

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Specified Technologies Inc., 200 Evans Way, Somerville, NJ 08876. Tel: (800) 992-1180, Fax: (908) 526-9623, Email: [techserv@stifirestop.com](mailto:techserv@stifirestop.com), Website: [www.stifirestop.com](http://www.stifirestop.com).
- B. Substitutions: Not permitted. No known equal.
- C. Single Source: Obtain firestop systems for each type of penetration and construction condition indicated only from a single manufacturer.

### 2.2 MATERIALS

- A. General: Use only firestopping products that have been tested for specific fire resistance rated construction conditions conforming to construction assembly type, penetrating item type, annular space requirements, and fire rating involved for each separate instance.
- B. Firestop Sealants: STI SpecSeal® Brand single component latex formulations that upon cure do not re-emulsify during exposure to moisture, the following products are acceptable:
  1. Specified Technologies Inc. (STI) SpecSeal® Series SSS Sealant
  2. Specified Technologies Inc. (STI) SpecSeal® Series LCI Sealant

- C. Firestop Putty: STI SpecSeal® Brand intumescent, non-hardening, water resistant putties containing no solvents, inorganic fibers or silicone compounds, the following products are acceptable:
  - 1. Specified Technologies Inc. (STI) SpecSeal® Series SSP Putty
- D. Firestop Pillows: STI SpecSeal® Brand re-enterable, non-curing, mineral fiber core encapsulated on six sides with intumescent coating contained in a flame retardant poly bag, the following products are acceptable:
  - 1. Specified Technologies Inc. (STI) SpecSeal® Series SSB Pillows
- E. Fire Rated Cable Pathways: STI EZ-PATH™ Brand device modules comprised of steel raceway with intumescent foam pads allowing 0 to 100 percent cable fill, the following products are acceptable:
  - 1. Specified Technologies Inc. (STI) EZ-PATH™ Fire Rated Pathway

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Before beginning installation, verify that substrate conditions previously installed under other sections are acceptable for installation of firestopping in accordance with manufacturer's installation instructions and technical information.
- B. Surfaces shall be free of dirt, grease, oil, scale, laitance, rust, release agents, water repellants, and any other substances that may inhibit optimum adhesion.
- C. Provide masking and temporary covering to protect adjacent surfaces.
- D. Do not proceed until unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. General: Install through-penetration firestop systems in accordance with Performance Criteria and in accordance with the conditions of testing and classification as specified in the published design.
- B. Manufacturer's Instructions: Comply with manufacturer's instructions for installation of firestopping products.

#### 3.3 FIELD QUALITY CONTROL

- A. Inspections: Owner shall engage qualified independent inspection agency to inspect through-penetration firestop systems.
- B. Keep areas of work accessible until inspection by authorities having jurisdiction.
- C. Where deficiencies are found, repair firestopping products so they comply with requirements.

### 3.4 ADJUSTING AND CLEANING

- A. Remove equipment, materials, and debris, leaving area in undamaged, clean condition.
- B. Clean all surfaces adjacent to sealed openings to be free of excess firestopping materials and soiling as work progresses.

### 3.5 SCHEDULES:

Review this list and update as required, Contact STI for assistance

Penetrant Type	Concrete Floor	Concrete Wall	Gypsum Board Wall
Blank Opening	C-AJ-0100, C-AJ-0101	C-AJ-0100, C-AJ-101	
Metal Conduits	C-AJ-1080, C-AJ-1240, C-AJ-1353	C-AJ-1080, W-J-1098, W-J-1100	W-L-1049, W-L-1222, W-L-1168
Plastic Conduits/ Raceways	C-AJ-2140, C-AJ-2292	W-J-2018, W-J-2076	W-L-2093, W-L-2241
Cables	C-AJ-3214, C-AJ-3231, F-A-3015	C-AJ-3214, C-AJ-3231, W-J-3098, W-J-3099	W-L-3218, W-L-3219
Cable Trays	C-AJ-4029	W-J-4021, W-J-4022, W-J-4033	W-L-4008, W-L-4029, W-L-4043

### 3.6 DOCUMENTATION

- A. Place system stickers on each side of wall penetrations.
- B. Place a reproduction (photo copy) of the UL System description in a document protector and mount to the wall next to the wall penetration
  - 1. Highlight the section of the system description that list the allowed cable types.

END OF SECTION